



Being Able to Access IEDs Remotely

PS2/Q4: ROD HUGHES (Australia)

rgh@rodhughesconsulting.com



Rod Hughes Consulting





Access any sub at “3am” in the morning

From home ...



which:

- Substation?
 - vendor’s IEDs are installed?
 - X system
 - Y system
 - Condition Monitoring
- Condition Monitoring Server or HMI platform is used to control locally?
 - Vendor A, B ... or Z HMI “standard”
 - Installed last year or 20 years ago
- IED firmware versions are installed?
- IED setting files versions are installed?
- IED setting software operating platform is required?
 - DOS, Windows 3.1 / 3.11 / NT / XP / 7 ... (... Windows42)
- IED setting software version is required?
- Remotely operated isolation and test equipment?




All through common access point and procedure!

Solutions need to provide

Ability to

- Access from any PC mobile device
 - Windows Remote Desktop
- Secure VPN and access control
- Connect to Central Unit
- Select site
- Remotely run software on local substation DCU
 - Virtual Machine for different platform requirements
 - Right software for right IEDs
- Access current site specific files on site server



<http://rodhughesconsulting.com/innovationandsolutions/>